

TECHNICAL SPECIFICATIONS AND OTHER ALLIED REQUIREMENTS

SI No.	Description of items	Quantity
PUR/259/ASL/AP/P/2021-22		
1	SUPPLY, INSTALLATION & COMMISSIONING OF SPARES FOR MGE GALAXY 5000 UPS (DETAILED SPECIFICATION AS PER ANNEXURE – I)	1 LOT

1. DELIVERY, INSTALLATION & COMMISSIONING:

The ordered goods are to be delivered, installed & commissioned at CSIR-CMERI, Durgapur within 120 days of receipt of Purchase Order. Installation should be carried out only by expert engineers of Supplier / Manufacturer. During the course of installation, necessary training on operation and maintenance of the goods shall be imparted to Institutes Scientist / Engineers/Technicians.

2. PERFORMANCE SECURITY:

3% of the Invoice value valid till 2 months beyond the warranty period.

3. PAYMENT TERM:

100% payment shall be paid within 30 days after delivery, satisfactory installation & commissioning of ordered goods upon submission of the Performance Security.

4. BID SECURING DECLARATION:

Bid Securing Declaration is to be submitted by the Bidder as per the format prescribed in the tender document.

5. OTHER CONDITIONS:

Cost of the material to be mentioned in the offer with Buyback & without Buyback option basis separately on PDF format.

6. WARRANTY:

03years warranty should be provided by the supplier from the date of satisfactory installation & commissioning.

Annexure - I

Sl.No	Part code	Description	Unit	Qty
1	LIBSESMG13IEC	Type S LIB Rack 13 modules with 3 years of Warranty	Nos	2
2	XXXX	3P 100 AMP DC MCCB WALL MOUNT ENCLOSURE RAL 9003	Nos	2
3	QCBL-QAMA12641-NSINR	Supply of Nyvin 6 Cable	Mtrs	30
4	QCBL-QAMA28253-NSINR	Lug 16sqmm	Nos	30
5	QCBL-QAMA30377-NSINR	4 Core Control cable	Mtrs	40
6	WSTRTUP-LB-01	(1) Startup Service for Li-ion Battery 1 rack solution	Nos	2
7	XXXX	Unloading, Shifting of LIB Rack with Accessories & 3rd Party Materials	Nos	2
8	XXXX	Retrofit activity	Lot	2
9	XXXX	Any other components, not mentined but required to complete the work	Lot	2

Buyback:

- Existing Lead-Acid battery as per below details:
Make: Exide
Rating: 12V, 120 AH
Number: 144

Notes:

- The offer should be complete in all respect considering the dismantling and loading (in vehicle) of the old batteries
- PBG@3% of the total contract value is to be provided during release of the final payment, valid till 60 days beyond warranty period
- GST Exemption certificate, as applicable to R&D institutions will be provided
- The battery racks are to be installed with 2 MGE Galaxy 5000 UPS which are running in ~~parallel~~ redundant mode

NA
09/12
Sudip Samanta
Himanshu
Samanta